



GROTON UTILITIES

Bozrah Light & Power Company

VENDING MACHINE OCCUPANCY CONTROLS - KILO-WATT HOUR SAVINGS LOOKUP TABLE

Vending Amps	Hours per Day - Vending Machine Shutoff											
	1	2	3	4	5	6	7	8	9	10	11	12
4	73	145	218	291	363	436	509	581	654	727	799	872
4.5	82	164	245	327	409	491	572	654	736	818	899	981
5	91	182	273	363	454	545	636	727	818	908	999	1090
5.5	100	200	300	400	500	600	699	799	899	999	1099	1199
6	109	218	327	436	545	654	763	872	981	1090	1199	1308
6.5	118	236	354	472	590	709	827	945	1063	1181	1299	1417
7	127	254	382	509	636	763	890	1017	1145	1272	1399	1526
7.5	136	273	409	545	681	818	954	1090	1226	1363	1499	1635
8	145	291	436	581	727	872	1017	1163	1308	1453	1599	1744
8.5	154	309	463	618	772	927	1081	1235	1390	1544	1699	1853
9	164	327	491	654	818	981	1145	1308	1472	1635	1799	1962
9.5	173	345	518	690	863	1036	1208	1381	1553	1726	1898	2071
10	182	363	545	727	908	1090	1272	1453	1635	1817	1998	2180
10.5	191	382	572	763	954	1145	1335	1526	1717	1908	2098	2289
11	200	400	600	799	999	1199	1399	1599	1799	1998	2198	2398
11.5	209	418	627	836	1045	1254	1462	1671	1880	2089	2298	2507
12	218	436	654	872	1090	1308	1526	1744	1962	2180	2398	2616
12.5	227	454	681	908	1135	1363	1590	1817	2044	2271	2498	2725
13	236	472	709	945	1181	1417	1653	1889	2126	2362	2598	2834
13.5	245	491	736	981	1226	1472	1717	1962	2207	2453	2698	2943
14	254	509	763	1017	1272	1526	1780	2035	2289	2543	2798	3052
14.5	263	527	790	1054	1317	1581	1844	2107	2371	2634	2898	3161
15	273	545	818	1090	1363	1635	1908	2180	2453	2725	2998	3270

Rebate not to exceed 35% of total project cost. Maximum annual rebate \$100,000. All rebates are at the sole discretion of the governing utility.