



NOTES:

1. FINAL 28 DAY CONCRETE CURE TO 4500 PSI.
2. #6 BARE COPPER GROUND WIRE & 5/8" x 8' CW GROUND ROD TO BE SUPPLIED AND INSTALLED BY CONTRACTOR.
3. 4' ARM ON 20' POLE, 6' ARM ON 25' POLE.

ORG. BY MRC  
07/05/07  
APPROVED

**PRECAST CONCRETE 20' & 25' STREETLIGHT BASE**

**GROTON UTILITIES**

CONSTRUCTION STANDARD

**E 12.400**

-

This page left intentionally blank.